

# Emergency Response Plan Dangerous Goods Information



DEPOT NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

SUBURB: \_\_\_\_\_ STATE: \_\_\_\_\_ POST CODE: \_\_\_\_\_

PHONE: \_\_\_\_\_ EMAIL: \_\_\_\_\_

## DANGEROUS GOODS STORED IN THIS DEPOT

<b>Substance</b>	Ethanol (Ethyl Alcohol)	<b>Capacity</b>	850 + 200 litres
<b>UN No.</b>	1077	<b>Typical Inventory</b>	600 Litres
<b>DG Class</b>	3	<b>Supplier</b>	ACB Group Pty Ltd
<b>Hazchem</b>	2[Y]E	<b>Supplier Contact</b>	03 9369 0220
<b>PG</b>	II	<b>Fire Brigade</b>	000

## DEPOT DESCRIPTION

Two approved Flammable Liquid cabinets.

One (850 litre capacity) is used for storage of closed packages.

The 200 litres cabinet is used for dispensing from a drum.

## DESCRIPTION OF SURROUNDINGS

Building is tilt-wall industrial complex, with warehouse at rear and office/showroom at front. Cabinets are in warehouse area.

# Emergency Response Plan

## Dangerous Goods Information

EMERGENCY SCENARIO	MAJOR RISKS	ACTIONS BY FIRST RESPONDER	INFORMATION FOR EMERGENCY SERVICES
<b>BUILDING ON FIRE</b>	Flammable liquid in packages or drum, in both cases contained in approved cabinets. Could produce toxic fumes on thermal decomposition of packaging etc.	<p>Evacuate area.</p> <p>RAISE THE ALARM (always raise the alarm before attempting fire fighting) IF SAFE TO DO SO, attack fire with extinguisher or water. Ensure accessible cabinets are closed.</p> <p>Make clear access for emergency vehicles.</p> <p>Provide emergency plan to Fire Brigade.</p> <p>Fire Brigade.</p> <p>Notify WorkCover.</p>	<p>Cabinets will provide protection to flammable contents.</p> <p>Forklift has LPG cylinder, and there are spare cylinders stored.</p>
<b>SPILL OF LIQUID</b>	Vapours are extremely flammable and may be toxic on contact or inhalation.	<p>Evacuate area and exclude ignition sources, including motor vehicles.</p> <p>RAISE THE ALARM</p> <p>Remove ignition sources.</p> <p>If safe to do so, use water mist to aid dispersion of vapours. Deploy spill kit.</p> <p>Notify WorkCover.</p>	<p>Most likely source of spill is forklift incident when handling palletised goods. Packages are small (4 litres, except for one 200 litre drum) so any spill is likely to be limited. For more than very minor spill, foam blanket is recommended.</p>
<b>PERSONNEL EXPOSURE to leak or vapour</b>	Skin or eye irritation. Breathing difficulty.	<p>Remove patient from store and apply first aid.</p>	<p>Usual PPE and controls required.</p>